

ANEXO 5 - Cálculo de caudales colector principal

Poblacion de la cabecera	53603	0.00%
Extension del casco urbano	178	0.00%
Densidad urbana	301.14	0.00%
		0.85

CONSUMO 140

TRAMO		L	Area drenada (Ha)		Q medio de AR	Coefficiente de infiltración	Qi	Coefficiente de conexiones erradas	Qe	Qm + Qi + Qe
DE	A	m	Propia	Acumulada	lps	l/s*Ha	lps	l/s*Ha	lps	lps
PZ213	PZ1	115.62	15.24	15.24	6.32	0.10	1.52	0.10	1.52	9.37
PZ1	PZ228	82.24	0.65	15.89	6.59	0.10	1.59	0.10	1.59	9.77
PZ228	PZ227	38.83	0.00	15.89	6.59	0.10	1.59	0.10	1.59	9.77
PZ227	PZ5	88.33	0.00	15.89	6.59	0.10	1.59	0.10	1.59	9.77
PZ5	PZ625	16.44	22.50	38.39	15.92	0.10	3.84	0.10	3.84	23.60
PZ625	PZ626	51.79	0.00	38.39	15.92	0.10	3.84	0.10	3.84	23.60
PZ626	PZ627	62.96	19.50	57.89	24.01	0.10	5.79	0.10	5.79	35.59
PZ627	PZ639	30.45	6.50	64.39	26.71	0.10	6.44	0.10	6.44	39.58
PZ639	PZ192	24.95	0.00	64.39	26.71	0.10	6.44	0.10	6.44	39.58
PZ192	PZ640	55.21	7.60	71.99	29.86	0.10	7.20	0.10	7.20	44.26
PZ640	PZ641	99.97	0.00	71.99	29.86	0.10	7.20	0.10	7.20	44.26
PZ641	PZ642	90.14	0.00	71.99	29.86	0.10	7.20	0.10	7.20	44.26
PZ642	PZ643	100.09	0.00	71.99	29.86	0.10	7.20	0.10	7.20	44.26
PZ643	PZ193	43.50	0.00	71.99	29.86	0.10	7.20	0.10	7.20	44.26
PZ193	PZ644	60.20	0.00	71.99	29.86	0.10	7.20	0.10	7.20	44.26
PZ644	PZ645	86.25	0.00	71.99	29.86	0.10	7.20	0.10	7.20	44.26
PZ645	PZ648	90.07	0.00	71.99	29.86	0.10	7.20	0.10	7.20	44.26
PZ648	PZ650	70.66	15.85	87.84	36.43	0.10	8.78	0.10	8.78	54.00
PZ650	PZ651	90.51	0.00	87.84	36.43	0.10	8.78	0.10	8.78	54.00
PZ651	PZ652	126.27	0.00	87.84	36.43	0.10	8.78	0.10	8.78	54.00